



SARAS 5.0

School Affiliation Re-Engineered Automation System



LETTER DETAILS

NO : CBSE/3430759/SS-00325-2526/2025-26

Dated: 04/10/2024

The Manager,
RTC PUBLIC SCHOOL
ANGARA, ANGARA, ANGARA
JHARKHAND, RANCHI, 835103
(M: 00000-00000000)

SUBJECT: -FRESH AFFILIATION UP TO SENIOR SECONDARY LEVEL-regarding.

Ref : Application No.: - SS-00325-2526 Dated:07/09/2024

Sir/Madam,

This is with reference to school application on the subject cited above. I am directed to convey approval of the Board for Fresh Affiliation up to Senior Secondary Level as per details given below :

Affiliation No used as User ID for both OASIS and LOC/Registration System	3430759
School No	67063
Password for OASIS and LOC/Registration Systems is same as that used for Affiliation Application.	
Affiliated for	Senior Secondary School Examination Class 1 to 12
Category	Fresh Affiliation
Period of affiliation	01.04.2025 to 31.03.2030

<https://saras.cbse.gov.in/SARAS/Status/ViewLetter>

1/5

Year and Month From which admission can be taken in Class-IX/XI	1 April,2025
Year and Month in which first batch of Class-X/XII will appear in board examinations	1 April,2027

Sl. No.	The school is directed to ensure that :
1	The total number of sections of the school from class I to XII shall be restricted to 25, of which not more than 8 sections may be used for senior secondary classes. The optimum number of the students shall be restricted to 40 for a classrooms size of 500 sq ft and above. Further, Increase of sections shall be subject to specific approval of the Board based on the request of the school as per affiliation bye law and availability of class rooms of greater than 500 sq ft dimension. The school is directed to run at least 01 section each of Bal-Vatika I, II & III in accordance with established norms permitted vide Board's circular no. 12/2023 dated 24-03-2023 & 25/2023 dated 11-09-2023.
2	Composite science lab has deficiencies. Utility like gas connections have not been seen on the work-stations. Safety measure i.e. fire extinguishers have not been installed in the lab. Further, plastic stools have been seen in the lab, which are prone to fire and are not appropriate furniture for labs. It should be replaced with sturdy lab furniture (wooden stools). The school shall accordingly upgrade the lab as per SoP issued by the Board within 3 months and submit compliance on SARAS with videography.
3	None of the science specific labs i.e. Physics, Chemistry and Biology lab have appropriate lab furniture. School has made provision of plastic stools, which should be replaced with appropriate study furniture. Further, no fire extinguisher is seen in the Chemistry lab. The school shall accordingly upgrade the labs as per SoP issued by the Board within 3 months and submit compliance on SARAS with videography.
4	Library is under-stocked and does not have enough stock of books for Senior Secondary level. School should have more books specially in reading section such as story books, novels, biographies etc. and other age appropriate books on different subjects and in different languages. Further, it does not have separate reading area for teachers/staff. School shall make provision of separate reading area and upgrade the library, within 03 months and submit compliance with videography.